

Date: March 22, 2024

Project: Lewis & Clark Electrical Upgrades

To: All Bidders

Project #: BS23044

From: Parker Amundson

Project Location: Yankton, SD

Addendum Number: 1

To: All prime contract bidders and all others to whom Drawings and Specifications have been issued by the Engineer. Acknowledge receipt of the Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as follows:

Clarifications

1. New transformers, remanufactured transformers, or any combination thereof are allowed on this project. Refer to specification section 26 1200 Medium-Voltage Transformers. Where remanufactured transformers are used they shall be rewound and reconditioned to like new standards.

END OF DOCUMENT – PA