



ADDENDUM NO. 1
7/27/18

Lodge Expansion and Renovation
Shadehill Recreation Area
Perkins County, South Dakota
Project No. Shad19Pa; OSE# G2118—08X/DEL

Bid Opening Date: August 9, 2018
3:00 PM CDT
Department of Game, Fish and Parks
2nd Floor, Foss Building
523 East Capitol
Pierre, South Dakota 57501-3182

Owner: State of South Dakota
Department of Game, Fish and Parks

Scope of this Addendum:

The following becomes a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the addendum on his bid form, incorporating its provisions in his bid.

Item No. 1: Concrete to follow specifications in project manual:
SECTION 03309 CAST-IN-PLACE CONCRETE

Item No. 2: Changes to Plan Sheet 5: Foundation Plan.

- Remove R-13 Kraft Faced insulation from rim joists:
 - Rim joists to be insulated with 3" thickness closed- cell spray foam insulation per IBC & IRC 2018 Regulations. R-value of insulation to be appropriate for the intended climate zone and location of installation on the project.
- Remove R-13 Kraft Faced Insulation from Crawl Space Walls:
 - Replace insulation on crawl space walls following the IBC & IRC code for crawl space insulation:



SOUTH DAKOTA DEPARTMENT OF GAME, FISH AND PARKS

523 EAST CAPITOL AVENUE | PIERRE, SD 57501

- Insulation to be Atlas EnergyShield Pro or approved equal. Information on Atlas EnergyShield Pro can be found at the following website:

<http://wall.atlasrwi.com/products/commercial/energyshield-pro/#tap-compliances>

Item No. 3: Plumbing fixtures on plan sheet 4:

- Provide plumbing fixtures as shown on plan sheet 4 or **approved equal products.**

Date: 7/27/18



Engineer II