

**ADDENDUM NO. 2**  
**January 17, 2020**

Mid-size Cabin  
Newton Hills State Park  
Lincoln County, South Dakota  
GFP Project No. Newt200a

Bid Opening Date: January 21, 2020, 3:00 PM CT  
Department of Game, Fish and Parks  
2nd Floor, Foss Building  
523 East Capitol  
Pierre, South Dakota 57501-3182

Owner: State of South Dakota  
Department of Game, Fish and Parks

Scope of this Addendum:

The following becomes a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the addendum on his bid form, incorporating its provisions in his bid.

- Item No. 1: Install TJERNLUND PRODUCTS, INC. XchangeR MODEL X2D or approved equal between floor joists or per manufacturer installation instructions for crawl space ventilation.
- Item No. 2: The interior 18" rim joists in the crawl space is to be spray foam insulation. The spray foam application must follow the International Residential Code (IRC) guidelines. The spray foam is to be applied at a 3" thickness.
- Item No. 3: Clarifications:
- A. The 6 mil. Poly Wrap is to cover entire floor and extend up the foundation wall 2'.
  - B. Exterior wall to be insulated with R-19 Kraft Insulation.
  - C. Grab bars for ADA Shower and toilet area are to be ASi- 3400 Series.
- Item No. 4: Corrections:
- A. Toilet on Pg. 5 of the plans to be **Model # 215AA.104.020** to meet ADA requirements.
  - B. Crawl space insulation to be 2" polystyrene foam board.

January 17th, 2020



---

Andrew Forest  
Assistant Building Engineer