

ADDENDUM NO. 3
July 6, 2021

Mina Lake Spillway Replacement
Mina Lake
Edmunds County, South Dakota
GFP Project No. Mina22Pa

Bid Opening Date: July 8th, 2021, 3:00 PM CT
Department of Game, Fish and Parks
2nd Floor, Foss Building
523 East Capitol
Pierre, South Dakota 57501-3182

Owner: State of South Dakota
Department of Game, Fish and Parks

Scope of this Addendum:

The following becomes a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the addendum on his bid form, incorporating its provisions in his bid.

Item No. 1: Specification Section 33 46 00, Sections 2.01 and 2.02 specify the use of both Standard Dimension Ration (SDR) 35 and Schedule 80 pipe. **All drainage pipe referenced in Section 33 46 00 shall be Schedule 80.**

Item No. 2: Detail 6 on Sheet 22 in the drawings shows a clean-out that consists of a 6" ID PVC Pipe that transitions to a 6" ID Galv. Steel Pipe. **The Contractor may substitute a 6" ID Schedule 80 PVC pipe in-place of the 6" ID Galv. Steel Pipe.**

July 6, 2021

James Gilkerson

James Gilkerson
Engineer II