

ADDENDUM NO. 1
April 28, 2016

Project: Storage Building
Aberdeen Office Complex
Brown County, South Dakota
Project No. Aber16Wa

Letting: Date: May 3, 2016
Time: 3:00 PM
Department of Game, Fish and Parks
2nd Floor, Foss Building
523 East Capitol
Pierre, South Dakota 57501-3182

Owner: State of South Dakota
Department of Game, Fish and Parks

Scope of this Addendum:

The following becomes a part of the original plans and specifications, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the addendum on his bid form, incorporating its provisions in his bid.

Item No. 1. TECHNICAL SPECIFICATIONS

SECTION 03309 CAST-IN-PLACE-CONCRETE

2.7 REINFORCEMENT MATERIALS

1. Deformed steel bars complying with ASTM-A615. Use grade 60 unless otherwise indicated.

2. All reinforcing steel shall be epoxy coated.

- **Remove Part 2- The reinforcing steel does not need to be epoxy coated.**

4-28-16

Date

Tyler Ulrich

Tyler Ulrich
Engineer I